


 PROVIDE M8755, LOW PRESSURE, LOW VOLUME SURGICAL ASPIRATOR, IN THE VICINITY OF THE RECOVERY ROOM.

KEY NOTES


- PROVIDE FLOOR DRAIN WITH FUNNEL OR FLOOR SINK.
- 2. PROVIDE A1165, IV TRACKS, FOR NAVY PROJECTS ONLY.
- PROVIDE AT LEAST ONE HANDWASHING FACILITY OR ONE FOR EVERY THIRD RECOVERY MODULE.
 P3200, ELECTRONIC LAVATORY, MAY BE USED INSTEAD OF P3100, LAVATORY. FOR THE P3200 PROVIDE EITHER BATTERY POWER OR HARD WIRED CONNECTION.
- 4. SIZE AND CONFIGURATION OF E0406, NURSE STATION, MAY VARY.
- 5. LENGTH OF E1500, WALL MOUNTED RAIL, TO BE DETERMINED BY MANUFACTURER/INSTALLER.
- 6. SEE ELEVATION OF A1107, UTILITY RAIL SYSTEM, FOR UTILITIES.
- 7. ALL CABINETS SHALL BE LOCKING.
- 8. MOUNT A5145, HOOK, AT 1372 [4'-6"] AFF.

RECOVERY ROOM, PHASE 1	(RRSS	<u>1) 4.0</u>	<u>4.05</u>
SURGERY (INPATIENT & AMBULATORY)	0	1000	2000
FLOOR/EQUIPMENT PLAN			
DATE: 01/28/2002	1:50	SCALE (MILLI	METERS)




 $\frac{\text{KEY NOTES}}{\text{1. PROVIDE A1165, IV TRACKS, FOR NAVY PROJECTS ONLY.}}$

RECOVERY ROOM, PHASE 1 (RRSS1) 4.04.05 1000 2000 SURGERY (INPATIENT & AMBULATORY) 0 FLOOR/EQUIPMENT PLAN DATE: 01/28/2002 SCALE (MILLIMETERS)



NORTH



WEST


NOTES

1. SEE TYPICAL EQUIPMENT MOUNTING HEIGHTS BEGINNING ON SHEET 7.01.01.

KEY NOTES

- 1. PROVIDE A1165, IV TRACKS, FOR NAVY PROJECTS ONLY.
- 2. PROVIDE AT LEAST ONE HANDWASHING FACILITY OR ONE FOR EVERY THIRD RECOVERY MODULE. P3200, ELECTRONIC LAVATORY, MAY BE USED INSTEAD OF P3100, LAVATORY. FOR THE P3200 PROVIDE EITHER BATTERY POWER OR HARD WIRED CONNECTION.
- 3. SEE ELEVATION OF A1107, UTILITY RAIL SYSTEM, FOR UTILITIES.

RECOVERY ROOM, PHASE 1 (RRSS1) 4.04.05 SURGERY (INPATIENT & AMBULATORY) 0 1000 2000 ELEVATIONS DATE: 01/28/2002 1:50 SCALE (MILLIMETERS)



EAST


NOTES

1. SEE TYPICAL EQUIPMENT MOUNTING HEIGHTS BEGINNING ON SHEET 7.01.01.

KEY NOTES

- LENGTH OF E1500, WALL MOUNTED RAIL, TO BE DETERMINED BY MANUFACTURER/INSTALLER.
- ALL CABINETS SHALL BE LOCKING.
 MOUNT A5145, HOOK, AT 1372 [4'-6"] AFF.

RECOVERY ROOM, PHASE 1 (RRSS1) 4.04.05 1000 2000 SURGERY (INPATIENT & AMBULATORY) 0 **ELEVATIONS** SCALE (MILLIMETERS) DATE: 01/28/2002 1:50



NOTES

- 1. THE UTILITIES AND DEVICES INDICATED ARE FOR AN EMERGENCY ROOM IN A HOSPITAL.
- 2. ALL RECEPTACLES IN HEADWALL SHALL BE HOSPITAL GRADE.

KEY NOTES

- 1. PROVIDE A1165, IV TRACKS FOR NAVY PROJECTS ONLY.
- 2. MONITOR SHELF.
- 3. SWITCH CONTROLS CEILING MOUNTED FLUORESCENT LIGHT FIXTURES.
- 4. TONE/VISUAL OR AUDIO/VISUAL PATIENT STATION AS REQUIRED BY THE USING MILITARY DEPARTMENT.
- 5. CODE BLUE AS REQUIRED BY USING MILITARY DEPARTMENT.
- 6. VACUUM SLIDE.
- TWO MOMENTARY CONTACT TOGGLE SWITCHES FOR CONTROL OF UP AND DOWN LIGHT SECTIONS OF FIXTURE M7435.

RECOVERY ROOM, PHASE 1 (RRSS1) 4.04.05 SURGERY (INPATIENT & AMBULATORY) 0 500 1000 ELEVATIONS DATE: 01/28/2002 1:30 SCALE (MILLIMETERS)

Medical Equipment Room Guide Plates

4.04 Surgery (Inpatient & Ambulatory)

Plate Number

4.04.05C

Room Name

RECOVERY ROOM, PHASE I (CUBICLE)

SEPS#

RRSS1

			Army	Navy	AF		Ţ	Jtili	tilities		
JSN	Nomenclature	Qty	Cat	Cat	Cat	1	2	3	4	5	6
A1107	Rail System , Utility, Gas and Electric	2	Α	Α	Α		F	G			Α
A1165	Track, IV, Ceiling Mounted, 7 Foot	4	Α	Α	Α						J
A5106	Waste Disposal Unit, Sharps w/Glove Dispenser	2	С	Α	С						
A5180	Track, Cubicle, Surface Mounted, With Curtain	2	Α	Α	Α						J
E0948	Cart, General Storage, Mobile, 42"H x 32"W x 22"D	2	С	С	С						
F0205	Chair, Side With Arms	1	С	С	С						
F0270	Chair, Rocking, High Back	1	С	С	С						
F0340	Stool, Self Adjusting	2	С	С	С						
F2000	Basket, Wastepaper, Round, Metal, 18 H x 16 Dia.	2	С	С	С						
F3200	Clock, Battery, 12" Diameter	2	С	С	С						
M0750	Flowmeter, Air, Connect w/50 PSI Supply	2	С	С	С			K			
M0755	Flowmeter, Oxygen, Low Flow	2	С	С	С			Α			
M0765	Regulator, Vacuum	6	С	С	С			В			
M3072	Frame, Infectious Waste Bag w/Lid	2	С	С	С						
M4100	Sphygmomanometer, Aneroid, Wall Mounted	2	С	С	С						
M4116	Monitor, Vital Signs	2	С	С	С		Α				
M4200	Otoscope/Ophthalmoscope, Wall Mounted	2	С	С	С		Α				
M4250	Pump, Syringe, Infusion	2	С	С	С		Α				
M4255	Stand, IV, Adjustable	2	С	С	С						
M4266	Pump, Volumetric, Infusion, Multiple Line	2	С	С	С		Α				
M4665	Stretcher, Recovery, Surgical	1	С	С	C						
M4816	Warming Unit, Patient, Automatic/Manual, Air	2	С	С	С		Α				
M 7015	Crib	1	С	С	С						
M7040	Table, Overbed	1	С	С	С						
M7405	Light, Exam, Ceiling Mounted	2	Α	Α	Α		F				J
M7435	Light, Overbed, Direct And Indirect	2	Α	Α	Α		F				J
M7845	Monitor, Physiological, Bedside, 4 Channel	2	С	С	С		Α				D
M7905	Oximeter, Pulse	2	С	С	С		Α				
M8755	Aspirator, Low Pressure/Low Volume, Surgical	1	С	С	С		Α				
M8810	Stand, Mayo	2	С	С	С						

Medical Equipment Room Guide Plates

4.04 Surgery (Inpatient & Ambulatory)

Plate Number

4.04.05A

Room Name

RECOVERY ROOM, PHASE I (CONTROL STATION)

SEPS#

RRSS1

			Army	Navy	AF	Utilities					
JSN	Nomenclature	Qty	Cat	Cat	Cat	1	2	3	4	5	6
A1066	Mirror, Float Glass, With SS Frame, 36X18	1	Α	Α	Α						J
A5075	Dispenser, Soap, Disposable	1	С	С	С						
A5080	Dispenser, Paper Towel, SS, Surface Mounted	1	Α	Α	Α						J
E0406	Nurse Station, Angle, Free Standing, 96" W	1	F	F	F		Α				
E0906	Locker, Supply, General, Wall Mtd, 23"W x 20"D	1	С	С	С						
E0912	Locker, Supply, Med Surg, Wall Mtd, 23"W x 20"D	1	С	С	С						
E0915	Locker, Supply, Medication, Wall Mtd, 23"W x 20"D	1	С	С	С						
E0954	Cart, Emergency, Mobile, 66"H x 52"W x 22"D	1	С	С	С						
E1500	Rail, MOD, W/MNTD, HX144XD	1	С	С	С						J
F0280	Chair, Swivel, Low Back	3	С	С	С						
F2000	Basket, Wastepaper, Round, Metal, 18 H x 16 Dia.	3	С	С	С						
M1800	Computer, Microprocessing	1	С	С	С		Α				
M1825	Printer, Computer	1	С	С	С		Α				
M1855	Facsimile Machine	1	С	С	С		Α				
M3070	Hamper, Linen, Mobile, w/Lid	1	С	С	С						
M3072	Frame, Infectious Waste Bag w/Lid	1	С	С	С						
M3110	Cabinet, Warming, F/S, 2 Heated Compartment, Elect	1	Α	Α	Α		F				
M4815	Hypo/Hyperthermia Unit, Automatic/Manual, Mobile	1	С	С	С		Α				
M7655	Defibrillator/Cardioscope, 5-Lead	1	С	С	С		Α				
M7850	Monitor, Physiological, Central, 8 Bed, Color	1	С	С	С		Α				D
P3100	Lavatory, Vitreous China, Slab Type	1	Α	Α	Α	D					
X3990	Illuminator, Film, 4 Panels, Wall Mounted	1	С	С	С		Α				

Medical Equipment Room Guide Plates

4.04 Surgery (Inpatient & Ambulatory)

Plate Number

4.04.05B

Room Name

RECOVERY ROOM, PHASE I (MEDI-PREP)

SEPS#

RRSS1

			Army	Navy	ΑF	Utilities						
JSN	Nomenclature	Qty	Cat	Cat	Cat	1	2	3	4	5	6	
A5075	Dispenser, Soap, Disposable	1	С	С	С							
A5080	Dispenser, Paper Towel, SS, Surface Mounted	1	Α	Α	Α						J	
A5106	Waste Disposal Unit, Sharps w/Glove Dispenser	1	С	Α	С							
A5145	Hook, Garment, Double, SS, Surface Mounted	1	Α	Α	Α						J	
C03P0	Cabinet, Sink, U/C/B, 2 Door, 36x30x22	1	Α	Α	Α							
C04H0	Cabinet, U/C/B, 2 Half Drawer, 3 Drawer, 36x36x22	1	Α	Α	Α							
CD040	Cabinet, W/H, 2 Shelf, 2 DO, Sloping Top, 38x36x13	1	Α	Α	Α						J	
CS010	Sink, SS, Single Compartment, 7.5x12x12 ID	1	Α	Α	Α	D						
CT030	Countertop, High Pressure Laminate	9	Α	Α	Α							
M3150	Distribution System, Medication, Automatic	1	С	С	С		Α					
M8172	Stimulator, Transcutaneous Electric Nerve	1	С	С	С		Α					
R4650	Ice Maker, Flaked, With Dispenser, 71x19x24	1	Α	Α	Α	В	В					
R6200	Refrigerator, U/C or F/S, 5 Cu Ft, 35x24x26	1	С	С	С		Α					